



Delivering water and power®

SRP Environmental Laboratory - AZ0081
998 W. Washington Street
Tempe, AZ 85281
(602) 236-4141

October 26, 2023

Tim Webley
East Valley Transformer Shop
7050 E University Drive
Mesa, AZ 85207

RE: WorkOrder 2310089
EVSC DERF

Enclosed are the results of analyses for samples received by our laboratory on 10/25/2023. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink that reads "Trina Erickson". The signature is written in a cursive style and is placed on a light gray rectangular background.

Trina Erickson
Laboratory Supervisor

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 10/26/2023 16:06

Samples in this Report

Lab ID	Sample	Matrix	Type	Qualifiers	Date/Time Sampled	Date Received
2310089-01	T3530405	Oil	Grab		10/25/2023 0:00	10/25/2023
2310089-02	T3530406	Oil	Grab		10/25/2023 0:00	10/25/2023

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 10/26/2023 16:06

Sample Results

Sample: T3530405
2310089-01 (Oil)

Date Sampled: 10/25/2023 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Data Analyzed by: Alternative Technologies, Inc.

Inorganic Chemistry

Silicon (Silicone fluid)	20		1	mg/L	D 7151	10/26/2023	ATI	
--------------------------	----	--	---	------	--------	------------	-----	--

Organic Chemistry

PCBs, total	BRL		1	ppm	EPA 600/4-81-045	10/26/2023	ATI	
-------------	-----	--	---	-----	------------------	------------	-----	--

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 10/26/2023 16:06

Sample: T3530406
2310089-02 (Oil)

Date Sampled: 10/25/2023 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Data Analyzed by: Alternative Technologies, Inc.

Inorganic Chemistry

Silicon (Silicone fluid)	29		1	mg/L	D 7151	10/26/2023	ATI	
--------------------------	----	--	---	------	--------	------------	-----	--

Organic Chemistry

PCBs, total	BRL		1	ppm	EPA 600/4-81-045	10/26/2023	ATI	
-------------	-----	--	---	-----	------------------	------------	-----	--

East Valley Transformer Shop
7050 E University Drive
Mesa, AZ 85207

Project: EVSC DERF
Project Number:
Project Manager: Tim Webley

Reported:
10/26/2023 16:06

Notes and Definitions

Item	Definition
BRL	Below Reporting Limit

SALT RIVER PROJECT

PO Box 52026, XCT310
 Phoenix, AZ 85072-2025
 (602) 236-4141



CHAIN OF CUSTODY RECORD/TRANSMITTAL

Environmental Services Department
 Laboratory & Field Services Division

Project: EVSC DERF

Charge No: _____

Project Manager / Contact: Tim Webley Phone: 6115

Cost Center: 23900

Sampler: (Signature) Thomas Rees

Sample ID Name and/or ID #	SRP Number and/or (Serial Number)	Sample Date	Lab ID #	Analysis	
				# Containers	PCB
T3530405	0123076 (876002496)	10/25/2023	matrix = oil 2310089-01	1	Y
T3530406	0081105 (194504)	10/25/2023	+ -02	1	Y

Sample Priority (Please Check)

- Emergency** Analysis performed immediately with verbal upon completion with written report to follow
- High Priority** Analysis and verbal under 4 days with written report within 10 days
- Routine** Analysis and verbal with written report within 10 days
- Verbal** Verbal on completion with written report to follow within 10 days
- Other Instructions** temp = Ambient

Relinquished By: (Signature) <u>Thomas Rees</u>	Date: 10/25/23	Time: 09:55	Received By: (Signature) <u>Deleisa J. Miller</u>	Date: 10/25/23	Time: 09:55	Comments:
---	--------------------------	-----------------------	---	--------------------------	-----------------------	------------------

Parameter Values:

Testing Dates: 10/25/2023 thru 10/25/2023

TEST RESULTS

Alternative Technologies, Inc.
12350 River Ridge Blvd.
Burnsville, MN 55337
Telephone (800) 255-8656 or (952) 894-3455

Trina Erickson
Salt River Project
PO Box 52025 Xct 310
Phoenix, AZ 86072-2025

Report Date: 26-Oct-23

Date Received: 26-Oct-23

SAMPLE IDENTIFICATION	LABORATORY NUMBER	RESULTS Silicon (Silicone fluid)
S/N: (NONE) CO#: 2310089-01	237619-001	7 ppm (20)
S/N: (NONE) CO#: 2310089-02	237619-002	10 ppm (29)
Silicone fluid concentration is the actual amount based on the elemental silicon ppm level		

Alternative Technologies, Inc., (ATI) shall assume no liability or responsibility, nor imply or express any warranty or other security against client loss of production, operation, profitability, or other loss, regardless of circumstances, beyond the cost of re-analysis by ATI.

Approved by: _____

TEST RESULTS

Alternative Technologies, Inc.

12350 River Ridge Blvd.
Burnsville, MN 55337
Telephone (800) 255-8656 or (952) 894-3455
Contact: Jamie Garvey

PCB CONTENT USEPA METHOD 8082A, 3580/3550, 3665

Trina Erickson
Salt River Project
PO Box 52025 Xct 310
Phoenix, AZ 86072-2025

Report Date: 26-Oct-23
Date Received: 26-Oct-23
Date Analyzed: 26-Oct-23

Arizona Lab License Number: AZ0626

SAMPLE IDENTIFICATION	LABORATORY NUMBER	AROCLOR	RESULTS
S/N: (NONE) CO#: 2310089-01	237619-001		<1 ppm
S/N: (NONE) CO#: 2310089-02	237619-002		<1 ppm

Alternative Technologies, Inc., (ATI) shall assume no liability or responsibility, nor imply or express any warranty or other security against client loss of production, operation, profitability, or other loss, regardless of circumstances, beyond the cost of re-analysis by ATI.

