



Delivering water and power®

SRP Environmental Laboratory - AZ0081
998 W. Washington Street
Tempe, AZ 85281
(602) 236-4141

September 19, 2023

Tim Webley
East Valley Transformer Shop
7050 E University Drive
Mesa, AZ 85207

RE: WorkOrder 2309053
EVSC DERF

Enclosed are the results of analyses for samples received by our laboratory on 9/18/2023. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink that reads "Trina Erickson". The signature is written in a cursive style and is contained within a light gray rectangular box.

Trina Erickson
Laboratory Supervisor

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 09/19/2023 12:15

Samples in this Report

Lab ID	Sample	Matrix	Type	Qualifiers	Date/Time Sampled	Date Received
2309053-01	T3522439	Oil	Grab		09/13/2023 0:00	09/18/2023
2309053-02	20230914105131	Oil	Grab		09/14/2023 0:00	09/18/2023
2309053-03	T3522764	Oil	Grab		09/15/2023 0:00	09/18/2023
2309053-04	T3523032	Oil	Grab		09/17/2023 0:00	09/18/2023
2309053-05	T3515685	Oil	Grab		09/18/2023 0:00	09/18/2023
2309053-06	20230918110925	Oil	Grab		09/18/2023 0:00	09/18/2023

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 09/19/2023 12:15

Sample Results

Sample: T3522439
2309053-01 (Oil)

Date Sampled: 09/13/2023 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
Organic Chemistry								
Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 09/19/2023 12:15

Sample: 20230914105131
2309053-02 (Oil)

Date Sampled: 09/14/2023 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 09/19/2023 12:15

Sample: T3522764
2309053-03 (Oil)

Date Sampled: 09/15/2023 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 09/19/2023 12:15

Sample: T3523032
2309053-04 (Oil)

Date Sampled: 09/17/2023 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 09/19/2023 12:15

Sample: T3515685
2309053-05 (Oil)

Date Sampled: 09/18/2023 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/18/2023	KSG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 09/19/2023 12:15

Sample: 20230918110925
2309053-06 (Oil)

Date Sampled: 09/18/2023 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/19/2023	KSG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/19/2023	KSG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/19/2023	KSG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/19/2023	KSG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/19/2023	KSG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/19/2023	KSG	
Aroclor 1260	6.5	1.0	1	mg/kg	EPA 600/4-81-045	09/19/2023	KSG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/19/2023	KSG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	09/19/2023	KSG	
PCBs, total	6.5	1.0	1	mg/kg	EPA 600/4-81-045	09/19/2023	KSG	

East Valley Transformer Shop
7050 E University Drive
Mesa, AZ 85207

Project: EVSC DERF
Project Number:
Project Manager: Tim Webley

Reported:
09/19/2023 12:15

Notes and Definitions

Item	Definition
BRL	Below Reporting Limit



Project: EVSC DERF

Charge No: _____

Project Manager / Contact: Jim Wewley Phone: 6115

Cost Center: 23900

Sampler: (Signature) Thomas R

Sample ID Name and/or ID #	SRP Number and/or (Serial Number)	Sample Date	Lab ID #	# Containers	Analysis	
					PCB	
T3522439	0108767 (3600194485)	9/13/2023	matrix = oil 2309053-1	1	Y	
20230914105131	(TANK 5)	9/14/2023	I	1	Y	
T3522764	0095788 (LG06A031)	9/15/2023	I	1	Y	
T3523032	0088300 (30150485)	9/17/2023	I	1	Y	
T3515685	0200081 (98M77828)	9/18/2023	I	1	Y	
20230918110925	(0644671)	9/18/2023	I	1	Y	

Sample Priority (Please Check)

- Emergency** Analysis performed immediately with verbal upon completion with written report to follow
- High Priority** Analysis and verbal under 4 days with written report within 10 days
- Routine** Analysis and verbal with written report within 10 days
- Verbal** Verbal on completion with written report to follow within 10 days
- Other Instructions** Temp = Ambient

Relinquished By: (Signature) <u>Thomas R</u>	Date: <u>9-18-23</u>	Time: <u>13:20</u>	Received By: (Signature) <u>Melissa J. Smith</u>	Date: <u>9/18/23</u>	Time: <u>1320</u>	Comments:
--	--------------------------------	------------------------------	--	--------------------------------	-----------------------------	------------------

Parameter Values:

Testing Dates: 9/13/2023 thru 9/18/2023