



Delivering water and power®

SRP Environmental Laboratory - AZ0081  
998 W. Washington Street  
Tempe, AZ 85281  
(602) 236-4141

June 23, 2020

Tim Webley  
East Valley Transformer Shop  
7050 E University Drive  
Mesa, AZ 85207

RE: WorkOrder 2006047  
EVSC DERF

Enclosed are the results of analyses for samples received by our laboratory on 6/11/2020. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read 'Robert M. Vertefeuille', is written over a light gray rectangular background.

Robert Vertefeuille  
Manager, Environmental Laboratory & Field Services

East Valley Transformer Shop  
 7050 E University Drive  
 Mesa, AZ 85207

Project: EVSC DERF  
 Project Number:  
 Project Manager: Tim Webley

**Reported:**  
 06/23/2020 15:22

### Samples in this Report

Lab ID	Sample	Matrix	Type	Qualifiers	Date/Time Sampled	Date Received
2006047-01	T3249020	Oil	Grab		05/21/2020 0:00	06/11/2020
2006047-02	T3249863	Oil	Grab		05/27/2020 0:00	06/11/2020
2006047-03	T3249868	Oil	Grab		05/27/2020 0:00	06/11/2020
2006047-04	T3250171	Oil	Grab		05/28/2020 0:00	06/11/2020
2006047-05	T3251274	Oil	Grab		06/03/2020 0:00	06/11/2020
2006047-06	T3251629	Oil	Grab		06/04/2020 0:00	06/11/2020
2006047-07	20200605124010	Oil	Grab		06/05/2020 0:00	06/11/2020
2006047-08	T3252018	Oil	Grab		06/08/2020 0:00	06/11/2020
2006047-09	T3252335	Oil	Grab		06/09/2020 0:00	06/11/2020
2006047-10	T3252705	Oil	Grab		06/10/2020 0:00	06/11/2020
2006047-11	T3252712	Oil	Grab		06/10/2020 0:00	06/11/2020
2006047-12	T3252716	Oil	Grab		06/10/2020 0:00	06/11/2020
2006047-13	T3252728	Oil	Grab		06/10/2020 0:00	06/11/2020
2006047-14	T3252733	Oil	Grab		06/10/2020 0:00	06/11/2020

East Valley Transformer Shop  
 7050 E University Drive  
 Mesa, AZ 85207

Project: EVSC DERF  
 Project Number:  
 Project Manager: Tim Webley

**Reported:**  
 06/23/2020 15:22

**Sample Results**

**Sample: T3249020**  
**2006047-01 (Oil)**

Date Sampled: 05/21/2020 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
<b>Organic Chemistry</b>								
Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	M1
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	

East Valley Transformer Shop  
 7050 E University Drive  
 Mesa, AZ 85207

Project: EVSC DERF  
 Project Number:  
 Project Manager: Tim Webley

**Reported:**  
 06/23/2020 15:22

**Sample: T3249863**  
**2006047-02 (Oil)**

Date Sampled: 05/27/2020 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

**Organic Chemistry**

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	

East Valley Transformer Shop  
 7050 E University Drive  
 Mesa, AZ 85207

Project: EVSC DERF  
 Project Number:  
 Project Manager: Tim Webley

**Reported:**  
 06/23/2020 15:22

**Sample: T3249868**  
**2006047-03 (Oil)**

Date Sampled: 05/27/2020 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

**Organic Chemistry**

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	

East Valley Transformer Shop  
 7050 E University Drive  
 Mesa, AZ 85207

Project: EVSC DERF  
 Project Number:  
 Project Manager: Tim Webley

**Reported:**  
 06/23/2020 15:22

**Sample: T3250171**  
**2006047-04 (Oil)**

Date Sampled: 05/28/2020 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

**Organic Chemistry**

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	

East Valley Transformer Shop  
 7050 E University Drive  
 Mesa, AZ 85207

Project: EVSC DERF  
 Project Number:  
 Project Manager: Tim Webley

**Reported:**  
 06/23/2020 15:22

**Sample: T3251274**  
**2006047-05 (Oil)**

Date Sampled: 06/03/2020 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

**Organic Chemistry**

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	

East Valley Transformer Shop  
 7050 E University Drive  
 Mesa, AZ 85207

Project: EVSC DERF  
 Project Number:  
 Project Manager: Tim Webley

**Reported:**  
 06/23/2020 15:22

**Sample: T3251629**  
**2006047-06 (Oil)**

Date Sampled: 06/04/2020 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

**Organic Chemistry**

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	



East Valley Transformer Shop  
 7050 E University Drive  
 Mesa, AZ 85207

Project: EVSC DERF  
 Project Number:  
 Project Manager: Tim Webley

**Reported:**  
 06/23/2020 15:22

**Sample: 20200605124010**  
**2006047-07 (Oil)**

Date Sampled: 06/05/2020 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

**Organic Chemistry**

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	

East Valley Transformer Shop  
 7050 E University Drive  
 Mesa, AZ 85207

Project: EVSC DERF  
 Project Number:  
 Project Manager: Tim Webley

**Reported:**  
 06/23/2020 15:22

**Sample: T3252018**  
**2006047-08 (Oil)**

Date Sampled: 06/08/2020 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

**Organic Chemistry**

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	

East Valley Transformer Shop  
 7050 E University Drive  
 Mesa, AZ 85207

Project: EVSC DERF  
 Project Number:  
 Project Manager: Tim Webley

**Reported:**  
 06/23/2020 15:22

**Sample: T3252335**  
**2006047-09 (Oil)**

Date Sampled: 06/09/2020 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

**Organic Chemistry**

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	

East Valley Transformer Shop  
 7050 E University Drive  
 Mesa, AZ 85207

Project: EVSC DERF  
 Project Number:  
 Project Manager: Tim Webley

**Reported:**  
 06/23/2020 15:22

**Sample: T3252705**  
**2006047-10 (Oil)**

Date Sampled: 06/10/2020 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

**Organic Chemistry**

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/17/2020	NJG	

East Valley Transformer Shop  
 7050 E University Drive  
 Mesa, AZ 85207

Project: EVSC DERF  
 Project Number:  
 Project Manager: Tim Webley

**Reported:**  
 06/23/2020 15:22

**Sample: T3252712**  
**2006047-11 (Oil)**

Date Sampled: 06/10/2020 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

**Organic Chemistry**

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	M1
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	

East Valley Transformer Shop  
 7050 E University Drive  
 Mesa, AZ 85207

Project: EVSC DERF  
 Project Number:  
 Project Manager: Tim Webley

**Reported:**  
 06/23/2020 15:22

**Sample: T3252716**  
**2006047-12 (Oil)**

Date Sampled: 06/10/2020 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

**Organic Chemistry**

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
<b>Aroclor 1254</b>	<b>1.0</b>	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
<b>PCBs, total</b>	<b>1.0</b>	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	

East Valley Transformer Shop  
 7050 E University Drive  
 Mesa, AZ 85207

Project: EVSC DERF  
 Project Number:  
 Project Manager: Tim Webley

**Reported:**  
 06/23/2020 15:22

**Sample: T3252728**  
**2006047-13 (Oil)**

Date Sampled: 06/10/2020 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

**Organic Chemistry**

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	

East Valley Transformer Shop  
 7050 E University Drive  
 Mesa, AZ 85207

Project: EVSC DERF  
 Project Number:  
 Project Manager: Tim Webley

**Reported:**  
 06/23/2020 15:22

**Sample: T3252733**  
**2006047-14 (Oil)**

Date Sampled: 06/10/2020 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

**Organic Chemistry**

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
<b>Aroclor 1254</b>	<b>1.0</b>	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	
<b>PCBs, total</b>	<b>1.0</b>	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2020	NJG	



East Valley Transformer Shop  
7050 E University Drive  
Mesa, AZ 85207

Project: EVSC DERF  
Project Number:  
Project Manager: Tim Webley

**Reported:**  
06/23/2020 15:22

### Notes and Definitions

<b>Item</b>	<b>Definition</b>
M1	Matrix spike recovery was high; the associated blank spike recovery was acceptable.
BRL	Below Reporting Limit

**SALT RIVER PROJECT**

PO Box 52026, XCT310  
Phoenix, AZ 85072-2025  
(602) 236-4141



**CHAIN OF CUSTODY RECORD/TRANSMITTAL**

Environmental Services Department  
Laboratory & Field Services Division

Project: EVSC DERF

Charge No: \_\_\_\_\_

Project Manager / Contact: Tim Webley Phone: 6115

Cost Center: 23900

Sampler: (Signature) Thomas R

						Analysis		
Sample ID Name and/or ID #	SRP Number and/or (Serial Number)	Sample Date			Lab ID #	# Containers	PCB	
T3249020	0038067 (C2893803)	5/21/2020		matrix = oil	2006047-1	1	Y	
T3249863	0076026 (7A354436)	5/27/2020		↓	-2	1	Y	
T3249868	0089879 (30188912)	5/27/2020			-3	1	Y	
T3250171	0094311 (846007519)	5/28/2020			-4	1	Y	
T3251274	0110000 (3603350785)	6/3/2020			-5	1	Y	
T3251629	0065691 (55764)	6/4/2020			-6	1	Y	
20200605124010	(26311A)	6/5/2020			-7	1	Y	
T3252018	0101806 (TAT75570703)	6/8/2020			-8	1	Y	
T3252335	0029553 (0091447)	6/9/2020			-9	1	Y	
T3252705	0068409 (050971A5)	6/10/2020			-10	1	Y	
T3252712	0020815 (C77898)	6/10/2020			-11	1	Y	
T3252716	0042052 (DV434011)	6/10/2020			-12	1	Y	
T3252728	0042051 (DV434008)	6/10/2020			-13	1	Y	

**Sample Priority (Please Check)**

- Emergency      Analysis performed immediately with verbal upon completion with written report to follow
- High Priority      Analysis and verbal under 4 days with written report within 10 days
- Routine      Analysis and verbal with written report within 10 days
- Verbal      Verbal on completion with written report to follow within 10 days
- Other Instructions

<b>Relinquished By: (Signature)</b> <u>[Signature]</u>	<b>Date:</b> 6-11-20	<b>Time:</b> 09:45	<b>Received By: (Signature)</b> <u>[Signature]</u>	<b>Date:</b> 6-11-20	<b>Time:</b> 0945	<b>Comments:</b>
---	-------------------------	-----------------------	---	-------------------------	----------------------	------------------

Parameter Values:

Testing Dates: 5/21/2020 thru 6/10/2020

Temp = Ambient

**SALT RIVER PROJECT**  
 PO Box 52026, XCT310  
 Phoenix, AZ 85072-2025  
 (602) 236-4141



**CHAIN OF CUSTODY RECORD/TRANSMITTAL**  
 Environmental Services Department  
 Laboratory & Field Services Division

Project: EVSC DERF

Charge No: \_\_\_\_\_

Project Manager / Contact: Tim Webley Phone: 6115

Cost Center: 23900

Sampler: (Signature) [Signature]

Sample ID Name and/or ID #	SRP Number and/or (Serial Number)	Sample Date			Lab ID #	Analysis		
						# Containers	PCB	
T3252733	0042050 (DV434006)	6/10/2020		matrix: oil	2006047-14	1	Y	

**Sample Priority (Please Check)**

- Emergency Analysis performed immediately with verbal upon completion with written report to follow
- High Priority Analysis and verbal under 4 days with written report within 10 days
- Routine Analysis and verbal with written report within 10 days
- Verbal Verbal on completion with written report to follow within 10 days
- Other Instructions

Relinquished By: (Signature)	Date:	Time:	Received By: (Signature)	Date:	Time:	Comments:
<u>[Signature]</u>	6-11-2020	0945	<u>[Signature]</u>	6-11-2020	0945	

Parameter Values:  
 Testing Dates: 5/21/2020 thru 6/10/2020

Temp = Ambient