



Delivering water and power®

SRP Environmental Laboratory - AZ0081
998 W. Washington Street
Tempe, AZ 85281
(602) 236-4141

June 18, 2021

Tim Webley
East Valley Transformer Shop
7050 E University Drive
Mesa, AZ 85207

RE: WorkOrder 2106070
EVSC DERF

Enclosed are the results of analyses for samples received by our laboratory on 6/17/2021. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink that reads "Trina Spangle". The signature is fluid and cursive.

Trina Spangle
Laboratory Supervisor

East Valley Transformer Shop
7050 E University Drive
Mesa, AZ 85207

Project: EVSC DERF
Project Number:
Project Manager: Tim Webley

Reported:
06/18/2021 15:40

Samples in this Report

<u>Lab ID</u>	<u>Sample</u>	<u>Matrix</u>	<u>Type</u>	<u>Qualifiers</u>	<u>Date/Time Sampled</u>	<u>Date Received</u>
2106070-01	T3333070	Oil	Grab		06/07/2021 0:00	06/17/2021
2106070-02	T3334156	Oil	Grab		06/11/2021 0:00	06/17/2021
2106070-03	T3334180	Oil	Grab		06/11/2021 0:00	06/17/2021
2106070-04	20210616145004	Oil	Grab		06/16/2021 0:00	06/17/2021

East Valley Transformer Shop
7050 E University Drive
Mesa, AZ 85207

Project: EVSC DERF
Project Number:
Project Manager: Tim Webley

Reported:
06/18/2021 15:40

Work Order Case Narrative

Sample 2106070-01 (T3333070) contains what appears to be a petroleum interference. A 10X dilution was performed to remove the interference from the chromatogram.

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 06/18/2021 15:40

Sample Results

Sample: T3333070
2106070-01 (Oil)

Date Sampled: 06/07/2021 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
Organic Chemistry								
Aroclor 1016	BRL	10	10	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	D1, N1
Aroclor 1221	BRL	10	10	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	D1, N1
Aroclor 1232	BRL	10	10	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	D1, N1
Aroclor 1242	BRL	10	10	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	D1, N1
Aroclor 1248	BRL	10	10	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	D1, N1
Aroclor 1254	BRL	10	10	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	D1, N1
Aroclor 1260	BRL	10	10	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	D1, M1, N1
Aroclor 1262	BRL	10	10	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	D1, N1
Aroclor 1268	BRL	10	10	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	D1, N1
PCBs, total	BRL	10	10	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	D1, N1

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 06/18/2021 15:40

Sample: T3334156
2106070-02 (Oil)

Date Sampled: 06/11/2021 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 06/18/2021 15:40

Sample: T3334180
2106070-03 (Oil)

Date Sampled: 06/11/2021 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
Aroclor 1254	2.2	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
Aroclor 1260	1.4	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
PCBs, total	3.6	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 06/18/2021 15:40

Sample: 20210616145004
2106070-04 (Oil)

Date Sampled: 06/16/2021 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	06/18/2021	NJG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 06/18/2021 15:40

Notes and Definitions

Item	Definition
D1	Sample required dilution due to matrix.
M1	Matrix spike recovery was high; the associated blank spike recovery was acceptable.
N1	See case narrative.
BRL	Below Reporting Limit

SALT RIVER PROJECT

PO Box 52026, XCT310
 Phoenix, AZ 85072-2025
 (602) 236-4141



CHAIN OF CUSTODY RECORD/TRANSMITTAL

Environmental Services Department
 Laboratory & Field Services Division

Project: EVSC DERF

Charge No: _____

Project Manager / Contact: Tim Webley Phone: 6115

Cost Center: 23900

Sampler: (Signature) Thomas R

Sample ID Name and/or ID #	SRP Number and/or (Serial Number)	Sample Date			Lab ID #	Analysis	
						# Containers	PCB
T3333070	0081108 (194501)	6/7/2021		matrix=oil	Z106070-1	1	Y
T3334156	0038831 (F446012)	6/11/2021		I	-2	1	Y
T3334180	0047063 (4915884)	6/11/2021		I	-3	1	Y
20210616145004	(BAKER TANK 1)	6/16/2021		I	-4	1	Y

Sample Priority (Please Check)

- Emergency** Analysis performed immediately with verbal upon completion with written report to follow
- High Priority** Analysis and verbal under 4 days with written report within 10 days
- Routine** Analysis and verbal with written report within 10 days
- Verbal** Verbal on completion with written report to follow within 10 days
- Other Instructions** temp = Ambient

Relinquished By: (Signature) <u>Thomas R</u>	Date: <u>6/17/21</u>	Time: <u>0805</u>	Received By: (Signature) <u>Helissa Jurell</u>	Date: <u>6/17/21</u>	Time: <u>0805</u>	Comments:
--	--------------------------------	-----------------------------	--	--------------------------------	-----------------------------	------------------

Parameter Values:

Testing Dates: 6/7/2021 thru 6/16/2021