



Delivering water and power®

SRP Environmental Laboratory - AZ0081  
998 W. Washington Street  
Tempe, AZ 85281  
(602) 236-4141

October 07, 2021

Tim Webley  
East Valley Transformer Shop  
7050 E University Drive  
Mesa, AZ 85207

RE: WorkOrder 2110024  
EVSC DERF

Enclosed are the results of analyses for samples received by our laboratory on 10/6/2021. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read 'Trina Spangle', is written over a light gray rectangular background.

Trina Spangle  
Laboratory Supervisor

East Valley Transformer Shop  
 7050 E University Drive  
 Mesa, AZ 85207

Project: EVSC DERF  
 Project Number:  
 Project Manager: Tim Webley

**Reported:**  
 10/07/2021 15:35

**Samples in this Report**

<b>Lab ID</b>	<b>Sample</b>	<b>Matrix</b>	<b>Type</b>	<b>Qualifiers</b>	<b>Date/Time Sampled</b>	<b>Date Received</b>
2110024-02	T3357944	Oil			09/28/2021 0:00	10/06/2021
2110024-03	20211006095732	Oil			10/06/2021 0:00	10/06/2021

East Valley Transformer Shop  
 7050 E University Drive  
 Mesa, AZ 85207

Project: EVSC DERF  
 Project Number:  
 Project Manager: Tim Webley

**Reported:**  
 10/07/2021 15:35

**Sample Results**

**Sample: T3357944**  
**2110024-02 (Oil)**

Date Sampled: 09/28/2021 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
<b>Organic Chemistry</b>								
Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/06/2021	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/06/2021	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/06/2021	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/06/2021	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/06/2021	NJG	
<b>Aroclor 1254</b>	<b>12</b>	1.0	1	mg/kg	EPA 600/4-81-045	10/06/2021	NJG	
<b>Aroclor 1260</b>	<b>12</b>	1.0	1	mg/kg	EPA 600/4-81-045	10/06/2021	NJG	M1
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/06/2021	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/06/2021	NJG	
<b>PCBs, total</b>	<b>24</b>	1.0	1	mg/kg	EPA 600/4-81-045	10/06/2021	NJG	

East Valley Transformer Shop  
 7050 E University Drive  
 Mesa, AZ 85207

Project: EVSC DERF  
 Project Number:  
 Project Manager: Tim Webley

**Reported:**  
 10/07/2021 15:35

**Sample: 20211006095732**  
**2110024-03 (Oil)**

Date Sampled: 10/06/2021 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

**Organic Chemistry**

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/06/2021	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/06/2021	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/06/2021	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/06/2021	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/06/2021	NJG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/06/2021	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/06/2021	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/06/2021	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/06/2021	NJG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/06/2021	NJG	

East Valley Transformer Shop  
7050 E University Drive  
Mesa, AZ 85207

Project: EVSC DERF  
Project Number:  
Project Manager: Tim Webley

**Reported:**  
10/07/2021 15:35

### Notes and Definitions

<b>Item</b>	<b>Definition</b>
M1	Matrix spike recovery was high; the associated blank spike recovery was acceptable.
BRL	Below Reporting Limit

**SALT RIVER PROJECT**

PO Box 52026, XCT310  
Phoenix, AZ 85072-2025  
(602) 236-4141



**CHAIN OF CUSTODY RECORD/TRANSMITTAL**

Environmental Services Department  
Laboratory & Field Services Division

Project: EVSC DERF

Charge No: \_\_\_\_\_

Project Manager / Contact: Tim Webley Phone: 6115

Cost Center: 23900

Sampler: (Signature) Thomas Rees

Sample ID Name and/or ID #	SRP Number and/or (Serial Number)	Sample Date	Lab ID #	Analysis		
				# Containers	PCB	
20210928072627	(TANK 6A)	9/28/2021	<u>ALREADY PROCESSED</u>	1	Y	
T3357944	0041717 (3746577)	9/28/2021	<u>2118024 - 2</u>	1	Y	
20211006095732	(PE15825)	10/6/2021	<u>- 3</u>	1	Y	

**Sample Priority (Please Check)**

- Emergency**      Analysis performed immediately with verbal upon completion with written report to follow
- High Priority**      Analysis and verbal under 4 days with written report within 10 days
- Routine**      Analysis and verbal with written report within 10 days
- Verbal**      Verbal on completion with written report to follow within 10 days
- Other Instructions**

<b>Relinquished By: (Signature)</b> <u>Thomas Rees</u>	<b>Date:</b> <u>10/6/21</u>	<b>Time:</b> <u>13:20</u>	<b>Received By: (Signature)</b> <u>R. Roberts</u>	<b>Date:</b> <u>10/6/21</u>	<b>Time:</b> <u>1320</u>	<b>Comments:</b>
---	--------------------------------	------------------------------	--	--------------------------------	-----------------------------	------------------

**Parameter Values:**

Testing Dates: 9/28/2021 thru 10/6/2021