



Delivering water and power®

SRP Environmental Laboratory - AZ0081  
998 W. Washington Street  
Tempe, AZ 85281  
(602) 236-4141

August 31, 2023

Tim Webley  
East Valley Transformer Shop  
7050 E University Drive  
Mesa, AZ 85207

RE: WorkOrder 2308069  
EVSC DERF

Enclosed are the results of analyses for samples received by our laboratory on 8/25/2023. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink that reads "Trina Erickson". The signature is written in a cursive style and is placed on a light gray rectangular background.

Trina Erickson  
Laboratory Supervisor

East Valley Transformer Shop  
 7050 E University Drive  
 Mesa, AZ 85207

Project: EVSC DERF  
 Project Number:  
 Project Manager: Tim Webley

**Reported:**  
 08/31/2023 15:23

### Samples in this Report

Lab ID	Sample	Matrix	Type	Qualifiers	Date/Time Sampled	Date Received
2308069-01	T3517988	Oil	Grab		08/24/2023 0:00	08/25/2023
2308069-02	T3518017	Oil	Grab		08/24/2023 0:00	08/25/2023
2308069-03	20230824125633	Oil	Grab		08/24/2023 0:00	08/25/2023
2308069-04	T3518083	Oil	Grab		08/24/2023 0:00	08/25/2023

East Valley Transformer Shop  
 7050 E University Drive  
 Mesa, AZ 85207

Project: EVSC DERF  
 Project Number:  
 Project Manager: Tim Webley

**Reported:**  
 08/31/2023 15:23

**Sample Results**

**Sample: T3517988**  
**2308069-01 (Oil)**

Date Sampled: 08/24/2023 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
<b>Organic Chemistry</b>								
Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	

East Valley Transformer Shop  
 7050 E University Drive  
 Mesa, AZ 85207

Project: EVSC DERF  
 Project Number:  
 Project Manager: Tim Webley

**Reported:**  
 08/31/2023 15:23

**Sample: T3518017**  
**2308069-02 (Oil)**

Date Sampled: 08/24/2023 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

**Organic Chemistry**

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	

East Valley Transformer Shop  
 7050 E University Drive  
 Mesa, AZ 85207

Project: EVSC DERF  
 Project Number:  
 Project Manager: Tim Webley

**Reported:**  
 08/31/2023 15:23

**Sample: 20230824125633**  
**2308069-03 (Oil)**

Date Sampled: 08/24/2023 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

**Organic Chemistry**

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	

East Valley Transformer Shop  
 7050 E University Drive  
 Mesa, AZ 85207

Project: EVSC DERF  
 Project Number:  
 Project Manager: Tim Webley

**Reported:**  
 08/31/2023 15:23

**Sample: T3518083**  
**2308069-04 (Oil)**

Date Sampled: 08/24/2023 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

**Organic Chemistry**

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	08/25/2023	KSG	

East Valley Transformer Shop  
7050 E University Drive  
Mesa, AZ 85207

Project: EVSC DERF  
Project Number:  
Project Manager: Tim Webley

**Reported:**  
08/31/2023 15:23

### Notes and Definitions

<b>Item</b>	<b>Definition</b>
-------------	-------------------

BRL	Below Reporting Limit
-----	-----------------------

**SALT RIVER PROJECT**

PO Box 52026, XCT310  
Phoenix, AZ 85072-2025  
(602) 236-4141



**CHAIN OF CUSTODY RECORD/TRANSMITTAL**

Environmental Services Department  
Laboratory & Field Services Division

Project: EVSC DERF

Charge No: \_\_\_\_\_

Project Manager / Contact: Jim Webley Phone: 6115

Cost Center: 23900

Sampler: (Signature) [Signature]

Sample ID Name and/or ID #	SRP Number and/or (Serial Number)	Sample Date	Lab ID #	Analysis		
				# Containers	PCB	
T3517988	0069608 (354374AA)	8/24/2023	matrix = oil 2308069-1	1	Y	
T3518017	0069503 (971474AA)	8/24/2023	-2	1	Y	
20230824125633	(TANK 4)	8/24/2023	-3	1	Y	
T3518083	0097833 (N235508TAUA)	8/24/2023	-4	1	Y	

**Sample Priority (Please Check)**

- Emergency Analysis performed immediately with verbal upon completion with written report to follow
- High Priority Analysis and verbal under 4 days with written report within 10 days
- Routine Analysis and verbal with written report within 10 days
- Verbal Verbal on completion with written report to follow within 10 days
- Other Instructions temp = Ambient

Relinquished By: (Signature) <u>[Signature]</u>	Date: <u>8/25/23</u>	Time: <u>10:35</u>	Received By: (Signature) <u>[Signature]</u>	Date: <u>8/25/23</u>	Time: <u>1035</u>	Comments:
---	----------------------	--------------------	---	----------------------	-------------------	-----------

**Parameter Values:**

Testing Dates: 8/24/2023 thru 8/24/2023