



Delivering water and power®

SRP Environmental Laboratory - AZ0081
998 W. Washington Street
Tempe, AZ 85281
(602) 236-4141

February 08, 2021

Tim Webley
East Valley Transformer Shop
7050 E University Drive
Mesa, AZ 85207

RE: WorkOrder 2101072
EVSC DERF

Enclosed are the results of analyses for samples received by our laboratory on 1/27/2021. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink, appearing to read 'Robert M. Vertefeuille', is written over a light gray rectangular background.

Robert Vertefeuille
Manager, Environmental Laboratory & Field Services

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 02/08/2021 12:51

Samples in this Report

Lab ID	Sample	Matrix	Type	Qualifiers	Date/Time Sampled	Date Received
2101072-01	20210125105026	Oil	Grab		01/25/2021 0:00	01/27/2021
2101072-02	20210125110441	Oil	Grab		01/25/2021 0:00	01/27/2021
2101072-03	20210125110842	Oil	Grab		01/25/2021 0:00	01/27/2021
2101072-04	20210125120634	Oil	Grab		01/25/2021 0:00	01/27/2021
2101072-05	20210125120644	Oil	Grab		01/25/2021 0:00	01/27/2021
2101072-06	20210125122228	Oil	Grab		01/25/2021 0:00	01/27/2021
2101072-07	20210125122637	Oil	Grab		01/25/2021 0:00	01/27/2021
2101072-08	20210125123407	Oil	Grab		01/25/2021 0:00	01/27/2021
2101072-09	20210125123910	Oil	Grab		01/25/2021 0:00	01/27/2021
2101072-10	20210125124327	Oil	Grab		01/25/2021 0:00	01/27/2021
2101072-11	T3296980	Oil	Grab		01/26/2021 0:00	01/27/2021

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 02/08/2021 12:51

Sample Results

Sample: 20210125105026
2101072-01 (Oil)

Date Sampled: 01/25/2021 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
Organic Chemistry								
Aroclor 1016	BRL	10	10	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1221	BRL	10	10	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1232	BRL	10	10	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1242	BRL	10	10	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1248	BRL	10	10	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1254	BRL	10	10	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1260	480	10	10	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1262	BRL	10	10	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1268	BRL	10	10	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
PCBs, total	480	10	10	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 02/08/2021 12:51

Sample: 20210125110441
2101072-02 (Oil)

Date Sampled: 01/25/2021 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
Organic Chemistry								
Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1260	12	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
PCBs, total	12	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 02/08/2021 12:51

Sample: 20210125110842
2101072-03 (Oil)

Date Sampled: 01/25/2021 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
Organic Chemistry								
Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1242	4.7	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
PCBs, total	4.7	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 02/08/2021 12:51

Sample: 20210125120634
2101072-04 (Oil)

Date Sampled: 01/25/2021 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
Organic Chemistry								
Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 02/08/2021 12:51

Sample: 20210125120644
2101072-05 (Oil)

Date Sampled: 01/25/2021 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 02/08/2021 12:51

Sample: 20210125122228
2101072-06 (Oil)

Date Sampled: 01/25/2021 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 02/08/2021 12:51

Sample: 20210125122637
2101072-07 (Oil)

Date Sampled: 01/25/2021 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 02/08/2021 12:51

Sample: 20210125123407
2101072-08 (Oil)

Date Sampled: 01/25/2021 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	11	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
PCBs, total	11	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 02/08/2021 12:51

Sample: 20210125123910
2101072-09 (Oil)

Date Sampled: 01/25/2021 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1254	1.0	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
PCBs, total	1.0	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 02/08/2021 12:51

Sample: 20210125124327
2101072-10 (Oil)

Date Sampled: 01/25/2021 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 02/08/2021 12:51

Sample: T3296980
2101072-11 (Oil)

Date Sampled: 01/26/2021 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	02/03/2021	NJG	

East Valley Transformer Shop
7050 E University Drive
Mesa, AZ 85207

Project: EVSC DERF
Project Number:
Project Manager: Tim Webley

Reported:
02/08/2021 12:51

Notes and Definitions

Item	Definition
BRL	Below Reporting Limit

SALT RIVER PROJECT

PO Box 52026, XCT310
Phoenix, AZ 85072-2025
(602) 236-4141



CHAIN OF CUSTODY RECORD/TRANSMITTAL

Environmental Services Department
Laboratory & Field Services Division

Project: EVSC DERF

Charge No: _____

Project Manager / Contact: _____

Phone: 6115

Cost Center: 23900

Sampler: (Signature) _____

Sample ID Name and/or ID #	SRP Number and/or (Serial Number)	Sample Date			Lab ID #	Analysis	
						# Containers	PCB
20210125105026	(12876)	1/25/2021		matrix = oil	Z10107Z-1	1	Y
20210125110441	(871)	1/25/2021			-2	1	Y
20210125110842	(205725)	1/25/2021			-3	1	Y
20210125120634	(63389)	1/25/2021			-4	1	Y
20210125120644	(8215354)	1/25/2021			-5	1	Y
20210125122228	(38622)	1/25/2021			-6	1	Y
20210125122637	(59295)	1/25/2021			-7	1	Y
20210125123407	(179939)	1/25/2021			-8	1	Y
20210125123910	(1428)	1/25/2021			-9	1	Y
20210125124327	(12521)	1/25/2021			-10	1	Y
T3296980	0071261 (109T74AA)	1/26/2021			-11	1	Y
20210126143750	(///)	1/26/2021				1	Y

mj 1/27/21

Sample Priority (Please Check)

- Emergency** Analysis performed immediately with verbal upon completion with written report to follow
- High Priority** Analysis and verbal under 4 days with written report within 10 days
- Routine** Analysis and verbal with written report within 10 days
- Verbal** Verbal on completion with written report to follow within 10 days
- Other Instructions**

Relinquished By: (Signature)	Date:	Time:	Received By: (Signature)	Date:	Time:	Comments:
	1-27-21	1005		1/27/21	1000	

Parameter Values:

Testing Dates: 1/25/2021 thru 1/26/2021