



Delivering water and power®

SRP Environmental Laboratory - AZ0081
998 W. Washington Street
Tempe, AZ 85281
(602) 236-4141

October 18, 2023

Tim Webley
East Valley Transformer Shop
7050 E University Drive
Mesa, AZ 85207

RE: WorkOrder 2310066
EVSC DERF

Enclosed are the results of analyses for samples received by our laboratory on 10/13/2023. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink that reads "Trina Erickson". The signature is written in a cursive style and is placed on a light gray rectangular background.

Trina Erickson
Laboratory Supervisor

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 10/18/2023 12:14

Samples in this Report

Lab ID	Sample	Matrix	Type	Qualifiers	Date/Time Sampled	Date Received
2310066-01	T3524188	Oil	Grab		09/23/2023 0:00	10/13/2023
2310066-02	20230924065205	Oil	Grab		09/24/2023 0:00	10/13/2023
2310066-03	T3524208	Oil	Grab		09/24/2023 0:00	10/13/2023
2310066-04	T3525163	Oil	Grab		09/28/2023 0:00	10/13/2023
2310066-05	20231002101254	Oil	Grab		10/02/2023 0:00	10/13/2023
2310066-06	T3526137	Oil	Grab		10/03/2023 0:00	10/13/2023
2310066-07	T3527185	Oil	Grab		10/09/2023 0:00	10/13/2023
2310066-08	T3527409	Oil	Grab		10/10/2023 0:00	10/13/2023
2310066-09	T3527573	Oil	Grab		10/11/2023 0:00	10/13/2023
2310066-10	T3527853	Oil	Grab		10/12/2023 0:00	10/13/2023
2310066-11	20231012131021	Oil	Grab		10/12/2023 0:00	10/13/2023

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 10/18/2023 12:14

Sample Results

Sample: T3524188
2310066-01 (Oil)

Date Sampled: 09/23/2023 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
Organic Chemistry								
Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 10/18/2023 12:14

Sample: 20230924065205
2310066-02 (Oil)

Date Sampled: 09/24/2023 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 10/18/2023 12:14

Sample: T3524208
2310066-03 (Oil)

Date Sampled: 09/24/2023 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 10/18/2023 12:14

Sample: T3525163
2310066-04 (Oil)

Date Sampled: 09/28/2023 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1242	4.0	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
PCBs, total	4.0	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 10/18/2023 12:14

Sample: 20231002101254
2310066-05 (Oil)

Date Sampled: 10/02/2023 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 10/18/2023 12:14

Sample: T3526137
2310066-06 (Oil)

Date Sampled: 10/03/2023 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 10/18/2023 12:14

Sample: T3527185
2310066-07 (Oil)

Date Sampled: 10/09/2023 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 10/18/2023 12:14

Sample: T3527409
2310066-08 (Oil)

Date Sampled: 10/10/2023 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 10/18/2023 12:14

Sample: T3527573
2310066-09 (Oil)

Date Sampled: 10/11/2023 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 10/18/2023 12:14

Sample: T3527853
2310066-10 (Oil)

Date Sampled: 10/12/2023 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	

East Valley Transformer Shop
 7050 E University Drive
 Mesa, AZ 85207

Project: EVSC DERF
 Project Number:
 Project Manager: Tim Webley

Reported:
 10/18/2023 12:14

Sample: 20231012131021
2310066-11 (Oil)

Date Sampled: 10/12/2023 0:00

Constituent	Result	Reporting Limit	Dilution	Units	Method	Analyzed Date	Analyst	Data Qualifier
-------------	--------	-----------------	----------	-------	--------	---------------	---------	----------------

Organic Chemistry

Aroclor 1016	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1221	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1232	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1242	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1248	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1254	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1260	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1262	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
Aroclor 1268	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	
PCBs, total	BRL	1.0	1	mg/kg	EPA 600/4-81-045	10/16/2023	KSG	

East Valley Transformer Shop
7050 E University Drive
Mesa, AZ 85207

Project: EVSC DERF
Project Number:
Project Manager: Tim Webley

Reported:
10/18/2023 12:14

Notes and Definitions

Item	Definition
-------------	-------------------

BRL	Below Reporting Limit
-----	-----------------------

SALT RIVER PROJECT

PO Box 52026, XCT310
Phoenix, AZ 85072-2025
(602) 236-4141

CHAIN OF CUSTODY RECORD/TRANSMISSION

Environmental Services Department
Laboratory & Field Services Division

Project: EVSC DERF

Charge No: _____

Project Manager / Contact: Tim Webley Phone: 6115

Cost Center: 23900

Sampler: (Signature) Thomas Rees

Sample ID Name and/or ID #	SRP Number and/or (Serial Number)	Sample Date	Lab ID #	Analysis		
				# Containers	PCB	
T3524188	0058886 (22002147)	9/23/2023	2310066-1	1	Y	
20230924065205	(IN CRATE / G815750101)	9/24/2023	-2	1	Y	
T3524208	0048289 (69372268)	9/24/2023	-3	1	Y	
T3525163	0074486 (AV895301)	9/28/2023	-4	1	Y	
20231002101254	(1002202301)	10/2/2023	-5	1	Y	
T3526137	0065985 (PEJ6452)	10/3/2023	-6	1	Y	
T3527185	0074212 (05098101)	10/9/2023	-7	1	Y	
T3527409	0106885 (841143604)	10/10/2023	-8	1	Y	
T3527573	0102172 (841017081)	10/11/2023	-9	1	Y	
T3527853	0088187 (15044180)	10/12/2023	-10	1	Y	
20231012131021	(TANK 4)	10/12/2023	-11	1	Y	

Sample Priority (Please Check)

- Emergency Analysis performed immediately with verbal upon completion with written report to follow
- High Priority Analysis and verbal under 4 days with written report within 10 days
- Routine Analysis and verbal with written report within 10 days
- Verbal Verbal on completion with written report to follow within 10 days
- Other Instructions Temp = Ambient

Relinquished By: (Signature) <u>Thomas Rees</u>	Date: <u>10/13/23</u>	Time: <u>10:30</u>	Received By: (Signature) <u>Melissa Jurell</u>	Date: <u>10/13/23</u>	Time: <u>1030</u>	Comments:
--	--------------------------	-----------------------	---	--------------------------	----------------------	-----------