

TEST RESULTS

Alternative Technologies, Inc.
 12350 River Ridge Blvd.
 Burnsville, MN 55337
 Telephone (800) 255-8656 or (952) 894-3455

PCB CONTENT USEPA METHOD 8082

Linda Johnson
 Salt River Project
 P.O. Box 52025, XCT310
 Phoenix, AZ 86072-2025

Report Date: 19-May-06

Date Received: 5-Apr-06

SPP# 92382
SNV# 11277

Arizona Lab License Number: AZ0626

SAMPLE IDENTIFICATION		LABORATORY NUMBER	AROGCOR	RESULTS
S/N: 101187 CO#: 48275	12317 Date Analyzed: 04/27/2006	136471-061		<1 ppm
S/N: 100730 CO#: 48276	12317 Date Analyzed: 04/27/2006	136471-062		<1 ppm
S/N: 92382 CO#: 48277	12317 Date Analyzed: 04/27/2006	136471-063		<1 ppm
S/N: 94107 CO#: 48264	12317 Date Analyzed: 04/27/2006	136471-064		<1 ppm
S/N: 85885 CO#: 48266	12317 Date Analyzed: 04/27/2006	136471-065		<1 ppm
S/N: 98087 CO#: 48267	12317 Date Analyzed: 04/27/2006	136471-066		<1 ppm
S/N: 98089 CO#: 48270	12317 Date Analyzed: 04/27/2006	136471-067		<1 ppm
S/N: 92007 CO#: 48271	12317 Date Analyzed: 04/27/2006	136471-068		<1 ppm
S/N: 93978 CO#: 48272	12317 Date Analyzed: 04/27/2006	136471-069		<1 ppm
S/N: 97814 CO#: 48261	12317 Date Analyzed: 04/27/2006	136471-070		<1 ppm

Alternative Technologies, Inc., (ATI) shall assume no liability or responsibility, nor imply or express any warranty or other security against client loss of production, operation, profitability, or other loss, regardless of circumstances, beyond the cost of re-analysis by ATI.

Approved by: 